

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 120

Dated: 05/02/2026

It is certified that an inspection team headed by **MR. BHARATRAM MEHAR, Assitant Engineer** from **Sub Division Office, Shajapur PHED** inspected the **ETERNAL SCHOOL OF STUDIES, A. B. Road, Barwal, SHAJAPUR** on **03/02/2026** and on the basis of Water Test Report (Attached) bearing no. **38/प्रयो.शा./कायं./लोस्वायां./2026** dated **04/02/2026** of **Sub Division Shahapur (PHED Lab)** certified that the **ETERNAL SCHOOL OF STUDIES** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 (One) Year



Signature with Seal: **Assistant Engineer**
P.H.E. Sub-Div. Shajapur

Name : **BHARATRAMRAM MEHAR**

Designation : **Assitant Engineer**

Name & Address of the Office / Department : **Sub Division Office**

PHED, SHAJAPUR

To

ETERNAL SCHOOL OF STUDIES,
A. B. Road, Barwal,
SHAJAPUR (M.P.) – 465001

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT LAL GHATI-SHAJAPUR
BLOCK-SHAJAPUR

Type Of Sample-SCHOOL

DATE-04/02/2026

Particulars of sender-PRINCIPAL ETERNAL SCHOOL OF STUDIES -ETR/PHE/FEB/2026/01/04-02-2026 A.B. ROAD BARWAL-SHAJAPUR

Particulars of sample- Collected/not collected by PHED

Sample No.	Place of Collection and details of Sample	Sample No.	Place of Collection and details of Sample
1	ETERNAL SCHOOL-BARWAL SHAJAPUR		

Parameter	Units	As per BIS 10500 2012 for Drinking Water		Sample 1									
		Requirement (desirable limit)	Permissible limit in the absence of alternate source										

PHYSICAL TEST

1	Temperature	°C	25								
2	Turbidity	NTU	1.0	5.0	1.0								
3	Colour	Hazen	5	15	5.0								
4	Odour	Agreeable	Disagreeable	Agreeable								
5	TASTE	Agreeable	Disagreeable	Agreeable								

CHEMICAL TEST

6	pH	pH scale	6.5 to 8.5	No Relaxation	7.6								
7	Total Hardness as CaCO ₃	Mg/l	200	600	335.2								
8	Calcium as Ca	Mg/l	75	200	116.0								
9	Magnesium as Mg	Mg/l	30	100	15.7								
10	Total alkalinity as CaCO ₃	Mg/l	200	600	260.8								
11	Chloride as Cl	Mg/l	250	1000	40.3								
12	Nitrate as NO ₃	Mg/l	45	45	-								
13*	Total Dissolved Solids	Mg/l	500	2000	406.0								
14	Iron	Mg/l	1.0	1.0	0.1								
15	Sulphate as SO ₄	Mg/l	200	400	-								
16	Fluoride as F	Mg/l	1.0	1.5	0.24								
17	Magnesium as Mn	Mg/l	0.1	0.3	0.0								
18	Residual Chlorine as Cl ₂	Mg/l	0.2	1.0	0.0								
19	Total coliform	Per100 MI	Nil	Nil	Nil								
20	Faecal coliform	Per100 MI		Nil	Nil								

- Note:-
1. This report should not be produced partly of full without approval of signatory authority for legal purposes.
 2. This recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" above which the source will have to be rejected.
 3. The results refer only to tested samples and parameters tested.
 4. Sample will be stored for a period of 10 days from the date of issue of report.
 5. This Lab does not hold any responsibility for variation in results for samples kept on hold for want of Clarification.


Chemist
Distt water testing laboratory
P.H.E.D. Shajapur


Assistant Engineer
Sub Division P.H.E.D.
Shajapur